

SAiGE Longlife Decking Ltd,

TEST REPORT

SCOPE OF WORK

Pedestal assy 585-920

REPORT NUMBER

210511021SHF-011

TEST DATE(S)

2021-05-11 - 2021-05-24

ISSUE DATE


2021-05-24

PAGES

6

DOCUMENT CONTROL NUMBER

LFT-APAC-SHF-OP-10k(May 1, 2021) © 2021 INTERTEK



Intertek Testing Services Shenzhen Ltd. Shanghai Fengxian Branch





Intertek Testing Services Shenzhen Ltd. Shanghai Fengxian Branch
Plant 5, No. 6958 Daye Road, Fengxian District, Shanghai, China
Tel: 021-61136116 Fax: 021-61189921

Website: www.intertek.com

Test Report

Statement

- 1. This report is invalid without company's special seal for testing on assigned page.
- 2. This report is invalid without authorized person's signature.
- 3. This report is invalid where any unauthorized modification indicated.
- 4.Don't copy this report in partial (except full copy) without any official approval in written by our company. This report is invalid without re-stamping the special seal for testing in copying report.

5.Any holder of this document is advised that this report is for the exclusive use of Intertek's Customer and is provided pursuant to the agreement between Intertek and its Customer. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. This report was made with due care within the limitation of a defined scope of work and on the basis of information, materials and instructions received from the Customer or its nominated third parties. Intertek is under no obligation to refer to or report upon any facts or circumstances which are outside the specific instructions received and accepts no responsibility to any parties whatsoever, following the issue of the report, for any matters arising outside the agreed scope of the works. The tests results are not intended to be a recommendation for any particular course of action. Customer is responsible for acting as it sees fit on the basis of such results.

6.Intertek's written consent is required to use Intertek's name or logo on the object, product or service being tested. The observations and test results in this report relate only to the sample under test. This report alone does not indicate that the item, product or service has passed any Intertek certification program.

7. The report was digital signed by Shang Hai, Intertek Group plc, please using Adobe Acrobat Reader to verify the authenticity.





Intertek Testing Services Shenzhen Ltd. Shanghai Fengxian Branch Plant 5, No. 6958 Daye Road, Fengxian District, Shanghai, China Tel: 021-61136116 Fax: 021-61189921

Website: www.intertek.com

Test Report

Issue Date: 2021-05-24 Intertek Report No. 210511021SHF-011

Applicant: SAiGE Longlife Decking Ltd,

Address: Vicarage Barns, Lower Quinton, Stratford-upon-Avon, Warwickshire, CV37 8SG, United Kingdom

Attn: Harriet

Test Type: Performance test, samples provided by the applicant.

Product Information

Product Name	Pedestal assy 585-920		Brand	Saige
Sample		Good Condition	Sample Amount	3 pcs
Description		Good Condition	Received Date	2021-05-07
Sample ID		Model	Specification	
S210511021SHF.001		PED-EX5-FR	585-920	

Test Methods And Standards

Test Standard	With reference to Section 5 of CISCA Recommended Test Procedures for Access Floors 2007
Specification Standard	/
Test Conclusion	The samples were tested according to the above standards, and the results are shown in the following page.

Note:

Report Authorized

Name: Daniel Zhang

Title: Approver

Name: Flora Fan

Title Reviewer

Jackie Zhou

Name: Jackie Zhou Title: Project Engineer

^{1.} This report relates specifically to the sample(s) that were drawn and provided by the applicant or their nominated third party. The reported result(s) provide no warranty or verification on the sample(s) representing any specific goods and/or shipment and only relate to the sample(s) as received and tested.



Test Report

Issue Date: 2021-05-24 Intertek Report No. 210511021SHF-011

Test Items, Method and Results:

Test Item: Pedestal axial load test

Test Method: With reference to Section 5 of CISCA Recommended Test Procedures for Access Floors 2007

Test Procedure:

Pedestals were tested according to Section 5 of CISCA Recommended Test Procedures for Access Floors 2007. Aligh the pedestal assembly in the testing apparatus and apply an increasing load centered on the pedestal until reached to the maximum load, then record the load and inspected the tested sample.

Results:

Pedestal	Ultimate Load (N)	
1	10850	
2	10205	
3	10670	
Average	10575	

Test Photo:




In test



Test Report

Issue Date: 2021-05-24 Intertek Report No. 210511021SHF-011

Drawings:







Test Report

Issue Date: 2021-05-24 Intertek Report No. 210511021SHF-011

Appendix A: Sample Received Photo



Revision:

NO.	Date	Changes
210511021SHF-011	2021-05-24	First issue

